

Certificate of Assessment

HF07ANK4753

No. 581

"Copyright CSIRO 2005 ©"
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by the CSIRO Division of Manufacturing and Infrastructure Technology in accordance with Australian/ New Zealand Standard 3837, Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter, 1998, at 50 kW/m², on behalf of:

Forbo Floorcoverings Pty. Ltd.
23 Ormsby Place
WETHERILL PARK NSW
AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNK 0266.

SAMPLE
IDENTIFICATION: Bulletin Board

DESCRIPTION OF
SAMPLE: The sponsor described the tested specimen as a homogeneous linoleum bulletin board comprising cork, linseed oil, filler and colour pigments. The specimen was backed with a jute backing.


Nominal total thickness: 6.0 mm
Nominal total mass: 4.3 kg/m²
Colour: light brown

SAMPLE
CLASSIFICATION: Group Number: Group 3
(In accordance with Specification A2.4 of the Building Code of Australia.)

Average specific extinction area: 384.8 m²/kg
(Refer to Specification C1.10a section 3(c) of the Building Code of Australia.)

Testing Officer: Bradley Paroz Date of Test: 16 February 2005

Issued on the 1st day of March 2005 without alterations or additions.



Garry E Collins
Manager, Fire Testing and Assessments



CSIRO Manufacturing & Infrastructure Technology
14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555